

How to log a water test result in the Argest portal

TE KURA O TE KAO ID: 1
6603D STATE HIGHWAY 1 TE KAO

Logout

Hello, you may have noticed the extra tabs on this screen, please feel free to look inside, as now you can download inspection forms, the BWOF, the schools Compliance Schedule etc so have a look around and if any questions please email TeamMOE@Argest.com and we will be happy to help you.

Owner's Inspections Water Testing Results Letters Your Compliance Documents Support

If your school is a self-supplier of drinking water, or water from a "non-compliant" water supply, please test your drinking water monthly. Retain all water lab test reports in the Water Testing section of the school Building Systems & Features Manual and log all tests including retests into Argest. If you have multiple treatment plants and/or have multiply self-supplying sites please use the Treatment Plant drop down box to record a test result for each treatment plant. Water test lab results are reported as a number in units of MPN (most probable number) and interpreted as follows;
* A test result reading of less than 1 (< 1) that is a Pass (< = Pass)
* A test result reading of 1 or greater than 1 (> 1) that is a Fail (> = Fail)
See the "Ministry Of Education Drinking Water In Schools" web page for more information about self-supplying your drinking water.

Water Testing History

New	Treatment Plant	Test Type	Sample Date	Coliform	Ecoli	Laboratory	Laboratory is Accredited	Entered By Name	Sample By Title	Sample By Name	Date Confirmed	Comments
February 2025	Treatment Plant 1	Monthly Monitoring Test	07/11/2024	Pass	Pass	Far North Lab Ltd Taipa	Yes	Hemi Takawe	Principal	Hemi Takawe	4/02/2025	
February 2025	Treatment Plant 1	Monthly Monitoring Test	06/12/2024	Pass	Pass	Far North Lab Ltd Taipa	Yes	Hemi Takawe	Principal	Hemi Takawe	4/02/2025	
May 2024	Treatment Plant 1	Monthly Monitoring Test	04/01/2024	Pass	Pass	Far North Lab Ltd Taipa	Yes	Hemi Takawe	Principal	Hemi Takawe	27/05/2024	
May 2024	Treatment Plant 1	Monthly Monitoring Test	08/02/2024	Pass	Pass	Far North Lab Ltd Taipa	Yes	Hemi Takawe	Principal	Hemi Takawe	27/05/2024	
May 2024	Treatment Plant 1	Monthly Monitoring Test	07/03/2024	Pass	Pass	Far North Lab Ltd Taipa	Yes	Hemi Takawe	Principal	Hemi Takawe	27/05/2024	
May 2024	Treatment Plant 1	Monthly Monitoring Test	04/04/2024	Pass	Pass	Far North Lab Ltd Taipa	Yes	Hemi Takawe	Principal	Hemi Takawe	27/05/2024	
May 2024	Treatment Plant 1	Monthly Monitoring Test	07/05/2024	Pass	Pass	Far North Lab Ltd Taipa	Yes	Hemi Takawe	Principal	Hemi Takawe	27/05/2024	
November 2023	Treatment Plant 1	Water Record - February 2025							Principal	Hemi Takawe	13/11/2023	
November 2023	Treatment Plant 1								Principal	Hemi Takawe	13/11/2023	
November 2023	Treatment Plant 1								Principal	Hemi Takawe	13/11/2023	
November 2023	Treatment Plant 1								Principal	Hemi Takawe	13/11/2023	
September 2023	Treatment Plant 1								Principal	Hemi Takawe	27/09/2023	

Water Record - February 2025

Treatment Plant: Treatment Plant 1

Test Type: Retest

Coliform:

Laboratory: Far North Lab Ltd Taipa

Sample By Title: Principal

Comments:

Sample Date:

Ecoli:

Entered By Name: Hemi Takawe

Sample By Name: Hemi Takawe

Update Cancel

2025 © Copyright by Argest

1 Click the **Water Testing Results** tab

2 Click **New**

3 Enter **Test Type**

a. Select **Monthly** for your first test result of a new month. A monthly test result **must be added** every month, regardless of retests.

b. Select **Retest** if your prior test result was a fail. You will need three passed retests in a row after one fail. Note: If your retesting carries into the next month, your third passed test must be entered under **Retest** but you can then enter the same test result as **Monthly**. This will save you doing a fourth retest in a new month.

4 Fill in all other fields, including any **Comments**. If you have more than one treatment plant, add the test result for each treatment plant by uniquely assigning the **Treatment Plant** tab.

5 When all fields are filled and comments made, click **Update**.